

2022  
**Annual Drinking Water Quality Report**  
**Brown's Creek Water Company**  
**DHEC #4420002**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water is purchased treated surface water (Broad River) from the City of Union. If you have any questions about this report or concerning your water utility, please contact Will Teaster. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday at 6:00pm at the Brown's Creek Water Office, 4287 Lockhart Hwy, Union, SC. A Source Water Assessment plan has been completed for our system by SCDHEC. If you do not have internet access, please contact Will Teaster at 864-424-9820 to make arrangements to review this document or to ask other questions.

Brown's Creek routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2022. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Action Level* - the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

*Treatment Technique (TT)* - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

<b>Regulated Substances Detected in Finished Drinking Water</b>						
Substance	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Chlorine (2022)	N	1.4 Range 1.2-1.4	ppm	4	4	Water additive used to control microbes
<b>Inorganic Contaminants (City of Union 2022)</b>						
Fluoride (2021)	N	.40 Range 0.35-35	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)	N	.32 Range 0.32-0.32	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium** Unregulated contaminant	N	14.0	ppm	N/A	N/A	Naturally occurring.
Radioactive Contaminants(2022)		Range of Level Detected	Units			
Beta/photon emitters	N	5.46 Range 5.46-5.46	mrem/year	0	4	Decay of natural and man-made deposits
<b>LEAD AND COPPER TEST RESULTS (Brown's Creek 2021)</b>						
Contaminant	Violation Y/N	90 <sup>th</sup> percentile	Unit Measurement	Action Level	Sites over action level	Likely Source of Contamination
Copper (2021)	N	.19	ppm	1.3	0	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead(2021)	N	0E-9	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits
<b>Volatile Organic Contaminants (2022)</b>						
Haloacetic Acids (HAAs)	N	14.0 Range 6.3-23.1	ppb	60	N/A	By-product of drinking water disinfectant
TTHM (Total trihalomethanes)	N	62 Range 26.4-50.7	ppb	80	N/A	By-product of drinking water chlorination

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Brown's Creek Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for

lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).